

**ADDENDUM 1**

**to the**

**ISSUE FOR BID**

**Task 1.2 Facility Modifications**

**for**

**Fayette County Coordinated Transportation (FACT)**

**825 Airport Road**

**Lemont Furnace, PA 15456**

**Contract No. FACT 13-13**

As a prospective bidder, please note the following revisions to the Contract Documents and Drawings for the above referenced project:

Bidders are hereby notified of the following changes:

**A. RESPONSE TO BIDDER QUESTIONS:**

1. On drawing A-1 there is a note showing "new parking". Is this "new parking" to be included in our proposal? If so can we get specifications on excavation, asphalt, etc.

**NO, parking is not part of contract FACT 13-13**

2. In the Table of Contents under Division 23 HVAC and Division 26 Electrical is listed "specifications listed on Drawings". I do not see any specifications on the drawings for either of these divisions. Please advise if these divisions are applicable to this project and if so where on the plans are they located.

**Division 23 and 26 are not applicable to this project**

3. Can you provide specifications for the flooring on this project? There is a note on the drawings to match existing but no specifications on the manufacturer or type to be able to provide accurate pricing.

**Assume the following: Mannington commercial Ultrabac RE. 20 ounce per square yard tufted yarn weight. Final color and pattern shall be determined during construction.**

End of Addendum #1