

Water, Sewer and Utility Systems

Existing Areas of Public Water Service

Albert Gallatin Municipal Authority serves Nicholson Township and Springhill Township. The Albert Gallatin Water Treatment Plant has a Public Water Supply Permit Number of 5260027. The plant's capacity is 540,000 gallons per day (GPD) and has a remaining capacity of 358,270 GPD. The plant draws 209,247 GPD from Cheat Lake. Albert Gallatin Municipal Authority has one pump station and five tanks that can hold 810,000 gallons. The Authority has 2,200 customers and charges a monthly fee of \$9.00 plus \$5.00 per 1,000 gallons used.

Belle Vernon Borough Municipal Authority serves Belle Vernon Borough, North Belle Vernon Borough, Rostraver Township, and Washington Township. The Belle Vernon Treatment Plant has a Public Water Supply Permit Number of 5260004. The plant's capacity is 1,000,000 GPD and has a remaining capacity of 481,121 GPD. The plant draws 518,879 GPD from the Monongahela River. Belle Vernon Borough Municipal Authority has zero pump stations and one reservoir that can hold 1,200,000 gallons. The Authority has 6,000 customers and charges quarterly rates of \$18.00 for the first 6,000 gallons and \$2.25 per 1,000 gallons used.

The Borough of Ohiopyle Water and Sewage Authority serves Ohiopyle Borough. The Ohiopyle Borough Treatment Plant has a Public Water Supply Permit Number of 5260015. The plant's capacity is 115,000 GPD and has a remaining capacity of 106,070 GPD. The plant draws 176,000 GPD from the Youghiogheny River. The Borough of Ohiopyle Water and Sewage Authority has zero pump stations and one standpipe that can hold 176,000 gallons. The Authority has 114 customers.

The Fairchance Borough Municipal Authority serves Fairchance Borough and Georges Township. The Fairchance Borough Water Treatment Plant has a Public Water Supply Permit Number of 5260007. The plant's capacity is 506,000 GPD and has a remaining capacity of 223,655 GPD. The plant draws from Askon Hollow and Cave Hollow. The Fairchance Borough Municipal Authority has zero pump stations and one tank that can hold 500,000 gallons. The Authority has 3,285 customers and charges monthly rates of \$18.50 for the first 4,000 gallons, then \$3.75 per 1,000 gallons used.

The Indian Creek Valley Water Authority serves Saltlick Township, Springfield Township, Bullskin Township, Connellsville Township, Donegal Township, Donegal Borough, and Mount Pleasant. The treatment plant has a Public Water Supply Permit Number of 5260011. The plant's capacity is 616,000 GPD and has 259,990 GPD of remaining capacity. The plant draws from Indian Creek/Mill Run Reservoir, Neals Run Well, Grimm Spring, and Pritts Spring. The Indian Creek Valley Water Authority has three pump stations and six tanks that can hold 1,632,000 gallons. The Authority has 6,000 customers and charges monthly rates of \$8.00 plus \$0.50 per 100 gallons used.

The Jefferson Township Authority serves only Jefferson Township. Jefferson Township has a Public Water Supply Permit Number of 5260034. Jefferson Township receives water from three separate water treatment plants. Jefferson Township has the capacity to receive 104,000 GPD and has 44,755 GPD of remaining capacity. Jefferson Township Authority has one pump station and two tanks that can hold 349,000 gallons. The Authority has 420 customers and charges quarterly rates of \$51.00 for the first 6,000 gallons, then \$4.00 per 1,000 gallons used.

Masontown Borough Authority serves Masontown Borough and German Township. The Masontown Borough Water Treatment Plant has a Public Water Supply Number of 5260013. The plant's capacity is 800,000 GPD and has a remaining capacity of 414,410 GPD. The plant draws 385,590 GPD from the Monongahela River. The Masontown Borough Authority has one pump station and one tank that can hold 1,000,000 gallons. The Authority has 3,715 customers and charges monthly rates of \$27.00 for the first 5,000 gallons, then \$2.50 per 1,000 gallons used.

Mountain Water Association serves Georges Township, German Township, Nicholson Township, and Springhill Township. Mountain Water Association has a Public Water Supply Permit Number of 5260032. Mountain Water Association receives water from North Fayette County Municipal Authority. Mountain Water Association has the capacity to receive 460,000 GPD and has a remaining transfer capacity of 185,164 GPD. Mountain Water Association has two pump stations and three tanks that can hold 460,000 gallons. The Association has 3,148 customers and charges monthly rates of \$12.50 for the first 3,000 gallons, then \$3.50 per 1,000 gallons used.

The Municipal Authority of Washington Township serves the areas of Allenport, Roscoe, Elco, Stockdale, Fayette City Borough, Washington Township, and Jefferson Township. The Municipal Authority of Washington County has a Public Water Supply Permit Number of 5260009. The Washington Township Treatment Plant has a 1,500,000 GPD capacity and a remaining capacity of 357,121 GPD. The plant draws 1,142,879 GPD from the Monongahela River. The Municipal Authority of Washington Township has one pump station and four tanks that can hold 1,729,000 gallons. The Authority has 8,600 customers and charges monthly rates of \$30.00 for the first 6,000 gallons, then \$2.00 per 1,000 gallons used.

The Municipal Authority of Westmoreland County serves Bullskin Township, Everson Borough, Perry Township, Upper Tyrone Township, South Connellsville Borough, plus portions of Allegheny County, Armstrong County, and Westmoreland County. The Municipal Authority of Westmoreland County has three water treatment plants. The George R. Sweeney Water Treatment Plant has a Public Water Supply of 5650032. The plant's capacity is 24,000,000 GPD and has a remaining capacity of 5,001,000 GPD. The plant draws 23,514,000 GPD from Beaver Run. The second treatment plant is Indian Creek Water Treatment Plant, which has a Public Water Supply Permit Number of 5260036. The plant's capacity is 50,000,000 GPD and has a remaining capacity of 29,106,000 GPD. The plant draws 25,912,000 GPD from the Youghiogheny River. The third treatment plant is the McKeesport Water Treatment Plant, which has a Public Water Supply Permit Number of 5020025. The plant's capacity is 10,000,000 GPD and has a remaining capacity of 2,550,000 GPD. The plant draws 7,823,000 GPD from the Youghiogheny River. The entire Municipal Authority of Westmoreland County system has 400,000 customers, 39 pump stations, and 57 tanks that can hold 97,230,000 gallons. The Authority charges quarterly rates of \$22.66 for the first 3,000 gallons, then \$3.14 per 1,000 gallons used.

Nemacolin Woodlands Resort Water System serves only the Nemacolin Woodlands Resort. The Nemacolin Woodlands Treatment Plant has a Public Water Supply Permit Number of 5260045. The plant's capacity is 500,000 GPD and has a remaining capacity of 399,274 GPD. The plant draws 100,726 GPD from Lake Louise I. The Nemacolin Woodlands Resort Water System has one pump station and one tank that can hold 569,000 gallons. The treatment plant can serve 400 customers and does not charge rates, as it is part of Nemacolin Woodlands Resort.

Newell Municipal Authority serves only Newell Borough. The Newell Municipal Authority Treatment Plant has a Public Water Supply Permit Number of 5260014. The plant's capacity is 600,000 GPD and has a remaining capacity of 244,000 GPD. The plant draws 356,000 GPD from the Monongahela River. The Newell Municipal Authority has zero pump stations and one standpipe that can hold 572,000 gallons. The Authority has 518 customers and charges \$25.50 per month for combined water and sewage service, assuming 3,000 gallons used for each.

North Fayette Municipal Authority serves the City of Uniontown, Dawson Borough, Dunbar Borough, Perryopolis Borough, Smithfield Borough, Vanderbilt Borough, Connellsville Township, Dunbar Township, Franklin Township, Georges Township, German Township, Lower Tyrone Township, Menallen Township, Nicholson Township, North Union Township, Perry Township, Redstone Township, South Union Township, Springhill Township, and Upper Tyrone Township. Wheeler Bottom Plant A has a Public Water Supply Permit Number of 5260019. The plant's capacity is 11,700,000 GPD and has 4,872,460 GPD remaining capacity. The plant draws 6,827,540 GPD from the Youghiogheny River. The North Fayette Municipal Authority has three pump stations and eleven tanks that can hold 13,877,000 gallons. The Authority has 32,981 customers and charges quarterly rates of \$54 for the first 15,000 gallons used.

PA American Water (Brownsville District) serves Brownsville Borough, West Brownsville, California, Coal Center Borough, Brownsville Township, Luzerne Township, Redstone Township, and Jefferson Township. The Penn American Water Brownsville Treatment Plant has a Public Water Supply Permit Number of 5260005. The plant's capacity is 31,000,000 GPD and has a remaining capacity of 29,682,801 GPD. The plant draws 1,451,798 GPD from the Monongahela River. The Brownsville District has three pump stations and one reservoir and three tanks that can hold 4,156,000 gallons. Penn American Water (Brownsville District) has 4,650 customers and charges monthly rates of \$9.30 plus \$0.438 per 100 gallons used.

Penn American Water (Connellsville District) serves the City of Connellsville, South Connellsville Borough, Connellsville Township, Bullskin Township, and Dunbar Township. Penn American Water (Connellsville District) has a Public Water Supply Number of 5260022. Penn American Water (Connellsville District) receives water from the Municipal Authority of Westmoreland County and North Fayette Municipal Authority. The transfer capacity is 3,264,011 GPD with a remaining capacity of 1,235,989 GPD. The system has one pump station and one tank that can hold 158,000 gallons. The Connellsville District has 13,320 customers and charges monthly rates of \$9.30 plus \$0.438 per 100 gallons used.

Penn American Water (Uniontown District) serves the City of Uniontown, South Union Township, North Union Township, Menallen Township, and Dunbar Township. Penn American Water (Uniontown District) has a Public Water Supply Number of 5260020. Penn American Water (Uniontown District) receives water from North Fayette Municipal Authority and Penn American Water (Brownsville District). The transfer capacity is 5,500,000 GPD and has 2,988,898 GPD remaining capacity. The Uniontown District has three pump stations and four tanks that can hold 3,600,000 gallons. The Uniontown District has 23,125 customers and charges monthly rates of \$9.30 plus \$0.438 per 100 gallons used.

Pleasant Valley Water Authority serves Bullskin Township and Connellsville Township. Pleasant Valley Water Authority has a Public Water Supply Permit Number of 5260006. Pleasant Valley receives 205,348 GPD from the Municipal Authority of Westmoreland County. The transfer capacity is 350,000 GPD with a remaining capacity of 144,652 GPD. Pleasant Valley Water Authority has one pump station and one tank that can hold 350,000 gallons. The Authority has 1,200 customers and charges quarterly rates of \$66.00 for the first 10,000 gallons, then \$5.06 per 1,000 gallons used.

Point Marion Borough Water Authority serves Point Marion Borough and Springhill Township. The Point Marion Water Treatment Plant has a Public Water Supply Permit Number of 5260017. The plant's capacity is 403,200 GPD and has a remaining capacity of 301,184 GPD. The plant draws 104,000 GPD from Cheat Lake. Point Marion Borough Water Authority has one pump station and one tank that can hold 530,000 gallons. The Authority has 1,350 customers and charges monthly rates of \$18.75 for the first 3,000 gallons, then \$4.25 per 1,000 gallons used.

Redstone Water Company, Inc. serves various areas of Redstone Township. Redstone Water Company has a Public Water Supply Permit Number of 5260025. Redstone Water Company receives 50,970 GPD from Southwest Water Authority and North Fayette Municipal Authority. The transfer capacity is 127,000 GPD and has 76,030 GPD of remaining capacity. Redstone Water Company has one pump station and one tank that can hold 127,000 gallons. The Authority has 1,056 customers and charges monthly rates of \$12.08 plus \$0.61 per 100 gallons used.

Southwestern PA Water Authority serves Center Township, Clarksville Borough, Cumberland Township, Deemston Borough, East Bethlehem Township, Franklin Township, Georges Township, German Township, Jefferson Borough, Jefferson Township, Luzerne Township, Menallen Township, Morgan Township, Redstone Township, Rices Landing Borough, Waynesburg Borough, Washington Township, and Whiteley Township. Tin Can Hollow Water Treatment Plant has a Public Water Supply Permit Number of 3092501. The plant's capacity is 9,000,000 GPD and has 5,247,044 GPD remaining capacity. The plant draws 3,752,956 GPD from the Monongahela River. The Authority has five pump stations and eleven tanks that can hold 11,985,000 gallons. The Authority has 33,675 customers and charges monthly rates of \$3.65 plus \$4.11 per 1,000 gallons.

Stateline Municipal Services Authority serves only Springhill Township. Stateline Municipal Services Authority has a Public Water Supply Permit Number of 5260035. Stateline receives water from Cheat View Public Service District. The transfer capacity is 28,500 GPD and has a remaining capacity of 24,613 GPD. Stateline has zero pump stations and zero storage facilities. The Authority has 73 customers and charges monthly rates of \$15.75 for the first 3,000 gallons, then \$0.03 per gallon used.

Tri-County Joint Municipal Authority serves only Luzerne Township in Fayette County. Tri-County has a Public Water Supply Permit Number of 5630045. The plant is located in Washington County and has a capacity of 2,100,000 GPD, with a remaining capacity of 1,250,000 GPD. The plant draws 3,000,000 GPD from the Monongahela River. Tri-County has zero pump stations and zero storage facilities in Fayette County. The Authority has 256 customers in Fayette County and charges quarterly rates of \$28.20 for the first 3,000 gallons, then \$3.75 per 1,000 gallons used.